

## **Consumer Notice of Lead and Copper Result**

Mississinawa Valley Local School District is a public water system (PWS) responsible for providing drinking water that meets state and federal standards. Drinking water samples for lead were collected at these locations and the result are:

**Action Level for Lead:** 15.5 micrograms per liter (ug/l)

**Location of samples:** 10480 Staudt Rd., Union City OH

**Sample Collection Dates:** September 18, 2018 and September 18, 2018

**PWS's lead 90<sup>th</sup> Percentile Value:** 0 micrograms per liter

Action Level 15 micrograms (ug/l) per liter

Location	Lead	Collection
	Level ug/l	Date
Kitchen North	0	9/18/18
Café West	0	9/18/18
HS Girls Shower	0	9/18/18
Elem. South DF	0	9/18/18
HS Boys Shower	0	9/18/18
Maint. Rm Sink	0	9/18/18
Elem. North DF	0	9/18/18
Elem. Prep Rm	0	9/18/18
HS Girls RR	0	9/18/18
Custodial Rm 306	1.36	9/18/18

This Tap Water Lead Result was less than 15 µg/L.

**What is being done:** *“Our 90<sup>th</sup> percentile value for lead does not exceed the action level, therefore, there are no actions being implemented at this time other than sharing this consumer notice.”*

**What does this mean?** *Under the authority of the Safe Drinking Water Act, the U.S. Environmental Protection Agency (EPA) set the action level for lead in drinking water at 15 ug/L. This means PWSs must ensure that water from taps used for human consumption do not exceed this level in at least 90 percent of the sites sampled (90<sup>th</sup> percentile value). The action level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a PWS must follow. Because lead may pose serious health risks, the EPA set a maximum Contaminant Level Goal (MCLG) of zero for lead. The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.*

**What are the health effects of lead?** *Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life. During pregnancy, the child received lead from the mother's bones, which may affect brain development.*

### **Where Can I Get Health Screenings and Testing of Blood Lead Levels?**

*Health Screenings are available through the Darke County Health Department. They can be contacted at 937-548-4196, [darkecountyhealth.org](http://darkecountyhealth.org), or email [darkecohnd@darkecountyhealth.org](mailto:darkecohnd@darkecountyhealth.org) located at 300 Garst Ave., Greenville, Ohio 45331*

### **What can I do to reduce exposure to lead if found in my drinking water?**

- Run your water to flush out lead. *If water has not been used for several hours, run water for thirty seconds to two minutes before using it for drinking or cooking. This helps flush any lead in the water that may have leached from the plumbing.*
- Use cold water for cooking and preparing baby formula. *Do not cook with, drink water, or make baby formula from the hot water tap. Lead dissolves more easily in hot water.*
- Do not boil water to remove lead. *Boiling water will not reduce lead.*

For more information please contact Mr. Doug Dunham, Superintendent, at (937) 968-5656, visit US EPA's website at [www.epa.gov/lead](http://www.epa.gov/lead), call the National Lead Information Center at 800-424-LEAD or contact your health care provider.